



August 13, 2014

**ADDENDUM #1  
IFB #15-18  
Water Main Repair Materials**

The number of this Addendum, Addendum No. 1, must be entered in the space provided on the Bid Form.

**CLARIFY:**

Could you please provide the width of WRC040-WRC160

Answer: Width on all repair clamps is 8-in. nominal.

Sincerely

P. Michael Vaughn  
Chief Procurement Officer