



September 17, 2014

ADDENDUM #1
IFB #15-34
O'CONNELL EXTERIOR DOOR PROJECT

IFB #15-35
LAURA LEE EXTERIOR DOOR PROJECT

IFB #15-36
LeBLANC EXTERIOR DOOR PROJECT

IFB #15-37
MOLLOY EXTERIOR DOOR PROJECT

The number of this Addendum, Addendum No. 1, must be entered in the space provided on the Bid Form, for each of the four bids.

CLARIFY:

Question: The specs call for prime finish of Hollow Metal Frames. We would like to propose the use of a prefinished frame. Our prefinished frames look better than field painted.

Answer: Hollow metal doors and/or frames may be provided with an optional factory finish in lieu of field painting. The products shall be cleaned, phosphatized and finished with a factory baked-on, rust-inhibitive finish paint in accordance with ANSI/SDIA250.3-2007 (R2011) *Test Procedure and Acceptance Criteria for Factory Applied Finish Steel Surfaces for Steel Doors and Frames*. Non-hollow metal prefinished frames are not acceptable."

Sincerely

P. Michael Vaughn
Chief Procurement Officer