



February 23, 2015

ADDENDUM #1
IFB #15-65
NEW FIRE ALARM CONTROL PANEL

The number of this Addendum, Addendum No. 1, must be entered in the space provided on the Bid Form.

REPLACE:

Sealed bids will be publicly opened on: **March 5, 2015** at City Hall in the Purchasing Department, Room 60, 375 Merrimack Street, Lowell, MA 01852, at 2:00 PM, EST/EDST, for the work described herein. **BIDDERS ARE REQUIRED TO SUBMIT A BID INCLUDING ALL BID FORMS CONTAINED IN THIS PACKAGE. DO NOT REMOVE PAGES.**

CLARIFY:

You only show on your specs for smoke detectors on 2nd floor hall and not sleeping areas. Do you want me to quote to install them in sleeping areas to meet code or is that going to be done at a later time.

- Quote now

You have a basement but you don't mention anything about it your specs. Do you want me to quote that or is that going to be done at a later time.

- The basement is not part of the scope

Do you want an annunciator and beacon quoted?

- YES

I don't see anything for strobes in the restrooms, do you want that quoted or is that going to be done at a later time.

- Quote now

I don't see anything regarding the devices in the stairway, do you want me to quote that or is that going to be done at a later time.

- Quote now

Also what is the ceiling height of the garage areas?

- 15 feet

Add Hardwired Carbon monoxide Alarms (to be installed where necessary)

All work performed must meet the fire and electrical for said work.

Sincerely


P. Michael Vaughn
Chief Procurement Officer