



September 4, 2015

**ADDENDUM #7**  
**IFB #16-22**  
**Leo A. Roy & Lower Locks**  
**Parking Garage Restoration Project**

The number of this Addendum, Addendum No. 7, must be entered in the space provided on the Bid Form.

**REPLACE:**

**DUE DATE – GENERAL BIDS**

Sealed bids will be publicly opened on: **September 15, 2015** at City Hall in the Purchasing Department, Room 60, 375 Merrimack Street, Lowell, MA 01852, at **11:00 AM, EST/EDST**, for the work described herein. **BIDDERS ARE REQUIRED TO SUBMIT A BID INCLUDING ALL BID FORMS CONTAINED IN THIS PACKAGE. DO NOT REMOVE PAGES.**

**CLARIFY:**

Detail 40.3/R603 directs to “remove and replace steel plate or bar stock flange connection”. Please provide a length considering this is a “per each” unit price item.  
Answer - The length of the plate or bar stock 4 inches.


Please provide existing garage construction plans or as-builts if available.  
Answer - The City will provide available original construction drawings to the successful bidder upon award of contract.

Measurement and payment for this “per each” item. Is one set of angles considered “one each”?

Answer – For Work Item 40.1 the unit price for “Each” is per set of angles.

This detail references, “shore: see note 3”, however, “note 3” does not reference shoring. It seems that this new installation would not require shoring. Please confirm.

Answer - That note is incorrect on Detail 40.1. Shoring is not required for this work.



Please provide a Measurement and Payment section for the unit prices. There are many items listed as "sf" the need clarification as to how this item would be measured (i.e. tee stem repairs, beam repairs, etc.)

Answer - The details provide sufficient information as to how the repairs will be measured, based on the depth of the repair.

Sheet R-302 references detail 21.1/R-501, however this detail and work item could not be found in the plans and specifications. Please advise.

Answer – Attached is Work Item description and Detail

Sincerely,

PM Vaughn  
Chief Procurement Officer