

September 11, 2015

ADDENDUM #1
IFB #16-35
Leak Correlation Survey

The number of this Addendum, Addendum No. 1, must be entered in the space provided on the Bid Form.

CLARIFY:

Can you provide a breakdown of pipe materials, size and approximate lengths of each?
Answer - The City does not have an accurate breakdown of the type of materials, size or lengths of each broken down. Most of the piping is cast iron 96% and ductile iron 4%. This is listed in a 2011 Drinking Water Study done by Woodard & Curran. There is no plastic or asbestos cement lined pipe.


Are maps/GIS records of the system available?

Answer - All the records are available on GIS but it's is on the in house hard drives.

Will there be a member of staff on hand to assist if required?

Answer - As stated in the contract there will be an in house staff person on hand if needed. This person will assist with issues only on an as needed basis.

Sincerely,


PM Vaughn
Chief Procurement Officer