The City of Lowell
City Hall • 375 Merrimack Street • Lowell, MA 01852
P: 978.970.4110 • F: 978.970.4114
www.LowellMA.gov

June 24, 2016

ADDENDUM #3
RFP #16-103
Proposed Bridge Rehabilitation Lawrence Street over Concord River

The number of this Addendum, Addendum No. 3, must be entered in the space provided on the Bid Form.

CLARIFY:

Well stay-in-place forms be allowed in the formwork of the bridge deck?

Answer – No, the intent is to have an exposed underside of concrete deck upon completion of the work.

Sincerely,

PM Vaughn
Chief Procurement Officer