



February 18, 2014

**ADDENDUM #2**  
**IFB #14-38**  
**WATER TRANSMISSION IMPROVEMENTS**

The number of this Addendum, Addendum No. 2, must be entered in the space provided on the Bid Form.

**CLARIFY:**

The pre-bid conference was not mandatory

**Question:**

In 2009, the LRWU conducted water main repairs in the area of this contract in similar scope to the proposed contract. L stop sleeves on the 36" and 24" water mains, in the locations shown on the drawings, were installed during this emergency water main repair contract. Is it acceptable to re-use the existing line stop sleeves that were installed during the emergency repair contract? Re-use of existing line stops would be a significant cost savings to the City. The Contractor who completed the Emergency repair has a significant advantage over all other bidders because he is aware of the location of the existing line stop sleeves and may be able to re-use the sleeves. Please provide the locations of the existing line stop sleeves, as it is necessary to determine if their locations allow them to be reused.

**Answer:**

Line Stops: Line Stops and Reset Line Stops shown on Drawings shall be REQUIRED. Reuse of existing line stops shall not be permitted. Removal of existing thrust restraints shall be required as noted on the Drawings.