

Meeting 6/2/21

Failed Food Establishments

Robinson School – 110 June St 5/12/21

Steamer and vat not working

Garbage disposal at three-bay sink not working

Last three inspections:

Reinspection:

Butler School – 1140 Gorham St 5/20/21

Hand sinks not reaching proper temp / repair immediately

Commercial fridge running off an extension cord / provide proper outlet/electrical source based on manufacturer's requirements

Last three inspections:

Reinspection: