

## Review of Utility Company Request for New Conduit/Pole Location

Applicant Information

Project Address

Utility  
(Select one) Electric

Tanner St (Post Realignment) & Plain St

Reason Install one (1) JO pole 13 and relocate two (2) JO poles 14 and 14-84 on Plain St as part of the Tanner Street Realignment project.

Date Submitted 12/8/2021

Review done by Daniel Lewis

Sidewalk Material Asphalt

**Note: Sidewalk material to be replaced in kind (Concrete in full panels only)**

Are Sidewalk Vaults present? YES  NO

Is Work on Street under a Paving Moratorium? YES  NO

Is this location within the Flood Plain? YES  NO

Are ADA requirements being met? YES  NO

### Comments

Coordinate with D.P.D./design consultant for exact locations of pole placement to ensure proper separation from utilities and minimum 4-ft of sidewalk access, as part of the Tanner Street Realignment project.

### Outcome of Review

Approved

Approved With  
Comments

Denied

Ting Chang, P.E.  
City Engineer

