

Review of Utility Company Request for New Conduit/Pole Location

Applicant Information

Project Address

Utility
(Select one) Electric

12 Wood St

Reason As part of the Rourke Bridge replacement project, the relocation of a new National Grid Electric utility pole will be required.

Date Submitted 12/2/2025

Review done by Joseph Cady

Sidewalk Material Concrete

Note: Sidewalk material to be replaced in kind (Concrete in full panels only)

Are Sidewalk Vaults present?

YES NO

Is Work on Street under a Paving Moratorium?

YES NO

Is this location within the Flood Plain?

YES NO

Are ADA requirements being met?


YES NO

Comments


No comment

Outcome of Review

Recommended



Recommended With
Comments



Not Recommended



David Beati, P.E.
Assistant City Engineer: David Beati