

Review of Utility Company Request for New Conduit/Pole Location

Applicant Information

Project Address

Utility
(Select one) Electric

1150 Westford St

Reason National Grid Electric is requesting permission to install a new utility pole with a recloser. A recloser helps improve reliability by automatically switching and restoring power after temporary outages

Date Submitted 9/22/2025

Review done by Joseph Cady

Sidewalk Material Asphalt

Note: Sidewalk material to be replaced in kind (Concrete in full panels only)

Are Sidewalk Vaults present? YES NO

Is Work on Street under a Paving Moratorium? YES NO

Is this location within the Flood Plain? YES NO


Are ADA requirements being met? YES NO

Comments


The pole shall be placed so as not to reduce the sidewalk clearance to less than 48 inches.

Outcome of Review


Recommended



Recommended With
Comments



Not Recommended



David Beati, P.E.

Assistant City Engineer: David Beati