



Thomas R. Bellegarde
Interim Assistant City Manager/Public Works Commissioner

To: Kevin J. Murphy, City Manager

From: Thomas R. Bellegarde, Assistant City Manager/Public Works Commissioner

Date: November 1, 2017

RE: Council Motion of 9.11 5/23/17 C. Samaras/C. Belanger

***Req. City Manager Have Proper Department Repair The Sidewalk At 478 Middlesex Street
In Front Of Sizzling Kitchen***

The City of Lowell Department of Public Works Engineering Division has inspected the sidewalk in front of Sizzling Kitchen and has determined that the damage is associated with a National Grid electrical vault and ventilation grates. National Grid has been contacted and been made aware of the situation.

DPW will coordinate with National Grid to have the electrical vault and the ventilation grates repaired along with the adjoining sidewalk. During this work, the Engineering Division will inspect the condition underneath the sidewalk and make plans for further repairs accordingly. The scope of work may be able to be included in the current project addressing the Downtown Cobblestone and sidewalk repair.

The Department of Public Works will update the Council with any and all progress.

Feel welcome to contact me with any questions you may have on this matter.